



BW 440 R

High rejection brackish water RO membrane with proven, long-lasting reliability

Key Features

- High salt rejection
- Good fouling resistance
- Good durability

Main Benefits

- High permeate water quality
- Long-lasting, reliable performance

Ideal Applications

- Industrial process water
- Municipal drinking water
- Water reuse


Performance Specifications

Item	Unit	Test Condition A	Test Condition B
Permeate Flow Rate	GPD (m ³ /d)	11,550 (43.7)	12,100 (45.8)
Stabilized Salt Rejection	%	99.6	99.65
Minimum Salt Rejection	%	99.5	99.56
Active Membrane Area	ft ² (m ²)	440 (41)	
Feed Spacer Thickness	mil	28	

The specifications outlined above are normalized performances based on the following test conditions:

- **Test Condition A:** 2,000 ppm NaCl, 225 psi (15.5 bar), 25°C (77°F), pH 7, Recovery 15%
- **Test Condition B (referential only):** 1,500 ppm NaCl, 225 psi (15.5 bar), 25°C (77°F), pH 7, Recovery 15%
- Permeate flow rates for individual elements may vary by +25/-15%

Dimensions and Weight



Dimensions: mm (in)			Wet Weight: kg (lbs)
A	B	C	16 (35)
Element Length	Element O.D.	Core Tube I.D.	
1,016 (40)	200 (7.9)	28.6 (1.125)	

All dimensional information is indicative and for reference only. Please contact NanoH2O for detailed technical specifications.

Operating Specifications

Specification	Unit	Value
Maximum Applied Pressure	psi (bar)	600 (41.3)
Maximum Chlorine Concentration	ppm	< 0.1
Maximum Operating Temperature	°C (°F)	45 (113)
pH Range, Continuous Operation		2-11
pH Range, Cleaning		2-12
Maximum Feed Water Turbidity	NTU	1.0
Maximum Feed Water SDI ₁₅		5.0
Maximum Feed Flow	gpm (m ³ /h)	75 (17)
Maximum Pressure Drop (ΔP) for Each Element	psi (bar)	15 (1.0)

These operating specifications are for general use. For specific applications, operation at more conservative values may ensure better performance and extended membrane life. See NanoH2O Technical Bulletins for more details.



Homepage



LinkedIn



Youtube



This product is certified to NSF/ANSI/CAN Standard 61 for drinking water systems